



Charlotte Storm Water
600 East Fourth Street
Charlotte, N C 28202-2844

Rezoning Petition Review

To: Planning, Design & Development

From: Doug Lozner

Date of Review: April 18, 2019

Rezoning Petition #: 19-42

Existing Zoning: B-2 (CD)

Proposed Zoning: TOD

Location of Property: Approximately 12.52 acres located on the southeast side of N Tryon St and University City Blvd.

Site Plan Submitted: No

Recommendations Concerning Storm Water: Flooding and surface water quality impacts associated with impervious surfaces on this site are being addressed through compliance with the Post-Construction Stormwater Ordinance. Compliance may include installing devices that hold and slowly release runoff over time to reduce flooding potential, devices that filter pollutants from runoff before release to streams, preservation of vegetated stream buffer zones, preservation of upland trees and forested areas, or paying a mitigation fee in-lieu-of onsite stormwater control devices. Compliance with the Post-Construction Stormwater Ordinance addresses concerns related to flooding and surface water impacts and therefore staff has no further comments.