



Petition #:	2019-046	Review Number:	1
Petition Respondent:	Bhavana Swayampakala	Date Reviewed:	4/23/2019
Phone Number:	704-336-4976	Email Address:	bhavana.swayampakala@charlottenc.gov

Comments:

Summary: Water is accessible for this rezoning boundary. Due to the limited project details that were provided, it is recommended that the applicant contact the Charlotte Water New Services group for further information and to discuss options regarding sanitary sewer system capacity.

Charlotte Water has accessible water system infrastructure for the rezoning boundary via an existing 6-inch and 12-inch water distribution main located along Mint Street and via an existing 8-inch water distribution main located along Palmer Street.

The proposed rezoning has the potential to significantly impact the capacity of the local sanitary sewer collection system. Due to the limited project details that were provided, it is recommended that the applicant contact the Charlotte Water New Services group for further information and to discuss options regarding sanitary sewer system capacity. Charlotte Water New Services group is available at (704) 432-2854.

Development is encouraged to contact Installation Development Services at (704) 336-5499 to review service connection design requirements and City Ordinances (e.g., backflow, separate meter Ordinance, public/private pipeline extensions). Comments: Submit application to the Capacity Assurance Program. Send plans to Charlotte Water for private water permitting (if applicable). Send plans to NCDEQ for private sewer permitting (if applicable).

Reservation of sanitary sewer system capacity through the Charlotte Water's Capacity Assurance Program is the responsibility of the customer/development. Contact the New Services Group at (704) 432-2854 for further information on reserving capacity up to 24 months.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. The findings do not imply available capacity in water and sanitary sewer lines, pump stations, or treatment facilities. Reservation of capacity is achieved through the Charlotte Water's Capacity Assurance Program.

