



Petition #:	2019-049	Review Number:	1
Petition Respondent:	Bhavana Swayampakala	Date Reviewed:	5/21/2019
Phone Number:	704-336-4976	Email Address:	bhavana.swayampakala@charlottenc.gov

Comments:

Summary: Charlotte Water currently does not have water or sewer infrastructure accessible for the rezoning boundary under review. The development will need to donate pipeline infrastructure to CLTWATER to serve this parcel. The applicant should contact Charlotte Water's New Services at (704) 432-2854 for more information regarding access to water system connections.

Charlotte Water currently does not have water system accessible for the rezoning boundary under review. The closest water distribution main is approximately 950 feet west of the rezoning boundary along Queen City Drive. A developer donated project will be required in cases there is not direct service. The applicant should contact Charlotte Water's New Services at (704) 432-2854 for more information regarding access to water system connections.

Charlotte Water currently does not have sewer system accessible for the rezoning boundary under review. The closest available sewer main is approximately 375 feet west of the rezoning boundary on Sheets Circle. A developer donated project will be required in cases there is not direct service. The applicant should contact Charlotte Water's New Services at (704) 432-2854 for more information regarding accessibility to sewer system connections.

Development is encouraged to contact Installation Development Services at (704) 336-5499 to review service connection design requirements and City Ordinances (e.g., backflow, separate meter Ordinance, public/private pipeline extensions). Comments: Submit application to the Capacity Assurance Program. Does not have direct access to water/sewer. Will need to acquire offsite easements to extend water/sewer services. No permanent structures located with CLTWATER easements. Contact our Donated Projects Department about extending water/sewer services.

Reservation of sanitary sewer system capacity through the Charlotte Water's Capacity Assurance Program is the responsibility of the customer/development. Contact the New Services Group at (704) 432-2854 for further information on reserving capacity up to 24 months.



This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. The findings do not imply available capacity in water and sanitary sewer lines, pump stations, or treatment facilities. Reservation of capacity is achieved through the Charlotte Water's Capacity Assurance Program.

