

| Acela Number | Luesa Number  |
|--------------|---|
| 2019-049     | Fire hydrant 750' from most remote point of building as truck travels   |
| 2019-050     | no comments   |
| 2019-051     | Fire hydrant 750' from most remote point of building as truck travels   |
| 2019-052     | See charlottefire.org for requirements  |
| 2019-053     | Fire hydrant 750' from most remote point of building as truck travels. 20' unobstructed clearance required on street at all times for CFD access. |
| 2019-054     | No comments   |
| 2019-055     | Fire hydrant 750' from most remote point of building as truck travels   |
| 2019-056     | Fire hydrant 750' from most remote point of building as truck travels, Access road within 150' nonsprinkled bldg; 200' sprinkled bldg             |
| 2019-057     | no comments   |
| 2019-058     | Fire hydrant 750' from most remote point of building as truck travels   |
| 2019-059     | Fire hydrant 750' from most remote point of building as truck travels   |
| 2019-060     | no comments   |
| 2019-061     | Fire hydrant 750' from most remote point of building as truck travels   |
| 2019-062     | Fire hydrant 750' from most remote point of building as truck travels   |
| 2019-063     | Fire hydrant 750' from most remote point of building as truck travels. See charlottefire.org for other requirements.                              |
| 2019-064     | Fire hydrant 750' from most remote point of building as truck travels. See charlottefire.org for other requirements.                              |