

Acela Number	Luesa Number
2019-049	Fire hydrant 750' from most remote point of building as truck travels
2019-050	no comments
2019-051	Fire hydrant 750' from most remote point of building as truck travels
2019-052	See charlottefire.org for requirements
2019-053	Fire hydrant 750' from most remote point of building as truck travels. 20' unobstructed clearance required on street at all times for CFD access.
2019-054	No comments
2019-055	Fire hydrant 750' from most remote point of building as truck travels
2019-056	Fire hydrant 750' from most remote point of building as truck travels, Access road within 150' nonsprinkled bldg; 200' sprinkled bldg
2019-057	no comments
2019-058	Fire hydrant 750' from most remote point of building as truck travels
2019-059	Fire hydrant 750' from most remote point of building as truck travels
2019-060	no comments
2019-061	Fire hydrant 750' from most remote point of building as truck travels
2019-062	Fire hydrant 750' from most remote point of building as truck travels
2019-063	Fire hydrant 750' from most remote point of building as truck travels. See charlottefire.org for other requirements.
2019-064	Fire hydrant 750' from most remote point of building as truck travels. See charlottefire.org for other requirements.