

| Acela Number | Luesa Number |
|--------------|---|
| 2019-049 | Fire hydrant 750' from most remote point of building as truck travels |
| 2019-050 | no comments |
| 2019-051 | Fire hydrant 750' from most remote point of building as truck travels |
| 2019-052 | See charlottefire.org for requirements |
| 2019-053 | Fire hydrant 750' from most remote point of building as truck travels. 20' unobstructed clearance required on street at all times for CFD access. |
| 2019-054 | No comments |
| 2019-055 | Fire hydrant 750' from most remote point of building as truck travels |
| 2019-056 | Fire hydrant 750' from most remote point of building as truck travels, Access road within 150' nonsprinkled bldg; 200' sprinkled bldg |
| 2019-057 | no comments |
| 2019-058 | Fire hydrant 750' from most remote point of building as truck travels |
| 2019-059 | Fire hydrant 750' from most remote point of building as truck travels |
| 2019-060 | no comments |
| 2019-061 | Fire hydrant 750' from most remote point of building as truck travels |
| 2019-062 | Fire hydrant 750' from most remote point of building as truck travels |
| 2019-063 | Fire hydrant 750' from most remote point of building as truck travels. See charlottefire.org for other requirements. |
| 2019-064 | Fire hydrant 750' from most remote point of building as truck travels. See charlottefire.org for other requirements. |