

2019-074.....Dead end fire apparatus access exceeding 150' requires approved turnaround minimum width 20' with turn radius 30' inside and 42' outside