

| | |
|-----------------|--|
| 2019-086 | No comment |
| 2019-087 | 1- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings. 2- Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs. 3- Fire department access road that exceeds 150' shall provide an approved turnaround. 4- Turn radius 30' inside and 42' outside. |
| 2019-088 | No comment |
| 2019-089 | Fire hydrant shall be located within 750' of most remote point of building as truck travels. Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs. Fire department access road that exceeds 150' shall provide an approved turnaround and radius is 30' inside and 42' outside. |
| 2019-090 | Fire hydrant shall be located within 750' of most remote point of building as truck travels. Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs. Fire department access road that exceeds 150' shall provide an approved turnaround and radius is 30' inside and 42' outside. |

| | |
|-----------------|---|
| 2019-091 | <p>Fire hydrant shall be located within 750' of most remote point of building as truck travels.</p> <p>Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs.</p> <p>Fire department access road that exceeds 150' shall provide an approved turnaround and radius is 30' inside and 42' outside.</p> |
| 2019-092 | <p>Fire hydrant shall be located within 750' of most remote point of building as truck travels.</p> <p>Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs.</p> <p>Fire department access road that exceeds 150' shall provide an approved turnaround and radius is 30' inside and 42' outside.</p> |
| 2019-093 | <p>Fire hydrant shall be located within 750' of most remote point of building as truck travels.</p> <p>Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs.</p> <p>Fire department access road that exceeds 150' shall provide an approved turnaround and radius is 30' inside and 42' outside.</p> |
| 2019-094 | <p>Fire hydrant shall be located within 750' of most remote point of building as truck travels.</p> <p>Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs.</p> <p>Fire department access road that exceeds 150' shall provide an approved turnaround and radius is 30' inside and 42' outside.</p> |

| | |
|-----------------|--|
| 2019-095 | Fire hydrant shall be located within 750' of most remote point of building as truck travels. Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs. Fire department access road that exceeds 150' shall provide an approved turnaround and radius is 30' inside and 42' outside. |
| 2019-096 | Fire hydrant shall be located within 750' of most remote point of building as truck travels. Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs. Fire department access road that exceeds 150' shall provide an approved turnaround and radius is 30' inside and 42' outside. |
| 2019-097 | Fire hydrant shall be located within 750' of most remote point of building as truck travels. Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs. Fire department access road that exceeds 150' shall provide an approved turnaround and radius is 30' inside and 42' outside. |
| 2019-098 | Fire hydrant shall be located within 750' of most remote point of building as truck travels. Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs. Fire department access road that exceeds 150' shall provide an approved turnaround and radius is 30' inside and 42' outside. |

| | |
|----------|---|
| 2019-099 | <p>Fire hydrant shall be located within 750' of most remote point of building as truck travels.</p> <p>Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs.</p> <p>Fire department access road that exceeds 150' shall provide an approved turnaround and radius is 30' inside and 42' outside.</p> |
| 2019-100 | <p>Fire hydrant shall be located within 750' of most remote point of building as truck travels.</p> <p>Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs.</p> <p>Fire department access road that exceeds 150' shall provide an approved turnaround and radius is 30' inside and 42' outside.</p> |
| 2019-101 | <p>Fire hydrant shall be located within 750' of most remote point of building as truck travels.</p> <p>Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs.</p> <p>Fire department access road that exceeds 150' shall provide an approved turnaround and radius is 30' inside and 42' outside.</p> |
| 2019-102 | No comment |
| 2019-103 | No comment |
| 2019-104 | No comment |