

2018-092 NO CHANGES TO PREVIOUS REVIEW COMMENTS

2018-150 NO CHANGES TO PREVIOUS REVIEW COMMENTS

2019-030 NO CHANGES TO PREVIOUS REVIEW COMMENTS

2019-047 (1) Fire hydrant shall be 750' from most remote point of bldg as truck travels. (2) Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs.... Private street A not in compliance with 20' access road. (4) Turn radius 30' inside and 42' outside. (5) For buildings that is equipped with a sprinkler system. A fire department connection shall be located within 200' of a fire hydrant for a 13 type sprinkler system and 750' for a 13R type sprinkler system.

2019-072 (1) Fire hydrant shall be within 750' of most remote point of building as fire truck travels. (2) 20' unobstructed clearance required on street at all times for CFD access. (3) Fire department access road that exceeds 150' shall provide an approved turnaround. (4) Turn radius 30' inside and 42' outside.

2019-093 DEAD END ACCESS ROAD THAT EXCEEDS 150' SHALL BE PROVIDED WITH AN APPROVED CFD TURNAROUND. ALSO SEE PREVIOUS COMMENTS

2019-098 NO CHANGES TO PREVIOUS REVIEW COMMENTS

2019-106 NO CHANGES TO PREVIOUS REVIEW COMMENTS

2019-107 NO CHANGES TO PREVIOUS REVIEW COMMENTS

2019-108 NO CHANGES TO PREVIOUS REVIEW COMMENTS