

Acela Number	
2019-105	1- Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs. 2- Fire department access road that exceeds 150' shall provide an approved turnaround. 3- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings. 4- For buildings that is equipped with a sprinkler system. A fire department connection shall be located within 200' of a fire hydrant for a 13 type
2019-106	No comment
2019-107	all buildings.
2019-108	of supporting 80,000 lbs.2-Fire department access road that exceeds 150' shall provide an approved turnaround. 3-Turn radius 30' inside and 42' outside.4- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings.
2019-109	for all buildings. 2-Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs. 3-Turn radius 30' inside and 42' outside.
2019-110	for all buildings. 2-Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs. 3-Turn radius 30' inside and 42' outside.
2019-111	No comments....existing building.
2019-112	1-Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs. 2- Fire department access road that exceeds 150' shall provide an approved turnaround. 3-Turn radius 30' inside and 42' outside. 4- Fire hydrant shall be located within 750' to the most remote

2019-113	No comment
2019-114	N/A
2019-115	No comment
2019-116	<p>1-Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs.</p> <p>2- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings. 3-Turn radius 30' inside and 42' outside. 4-For buildings that is equipped with a sprinkler system. A fire department connection shall be located within 200' of a fire hydrant for a 13 type sprinkler system and 750' for a 13R type sprinkler system.</p>
2019-117	<p>Fire hydrant shall be located within 750' of most remote point of building as truck travels.</p> <p>Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs.</p>
2019-118	<p>1-Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs.</p> <p>2- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings. 3-Turn radius 30' inside and 42' outside. 4-For buildings that is equipped with a sprinkler system. A fire department connection shall be located within 200' of a fire hydrant for a 13 type sprinkler system and 750' for a 13R type sprinkler system.</p>
2019-119	No comment
2019-120	<p>1-Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs.</p> <p>2- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings. 3-Turn radius 30' inside and 42' outside. 4-For buildings that is equipped with a sprinkler system. A fire department connection shall be located within 200' of a fire hydrant for a 13 type sprinkler system and 750' for a 13R type sprinkler system.</p>
2019-121	No comment