

| Acela Number | |
|--------------|---|
| 2019-105 | 1- Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs. 2- Fire department access road that exceeds 150' shall provide an approved turnaround. 3- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings. 4- For buildings that is equipped with a sprinkler system. A fire department connection shall be located within 200' of a fire hydrant for a 13 type |
| 2019-106 | No comment |
| 2019-107 | all buildings. |
| 2019-108 | of supporting 80,000 lbs.2-Fire department access road that exceeds 150' shall provide an approved turnaround. 3-Turn radius 30' inside and 42' outside.4- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings. |
| 2019-109 | for all buildings. 2-Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs. 3-Turn radius 30' inside and 42' outside. |
| 2019-110 | for all buildings. 2-Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs. 3-Turn radius 30' inside and 42' outside. |
| 2019-111 | No comments....existing building. |
| 2019-112 | 1-Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs. 2- Fire department access road that exceeds 150' shall provide an approved turnaround. 3-Turn radius 30' inside and 42' outside. 4- Fire hydrant shall be located within 750' to the most remote |

| | |
|-----------------|---|
| 2019-113 | No comment |
| 2019-114 | N/A |
| 2019-115 | No comment |
| 2019-116 | <p>1-Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs.</p> <p>2- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings. 3-Turn radius 30' inside and 42' outside. 4-For buildings that is equipped with a sprinkler system. A fire department connection shall be located within 200' of a fire hydrant for a 13 type sprinkler system and 750' for a 13R type sprinkler system.</p> |
| 2019-117 | <p>Fire hydrant shall be located within 750' of most remote point of building as truck travels.</p> <p>Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs.</p> |
| 2019-118 | <p>1-Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs.</p> <p>2- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings. 3-Turn radius 30' inside and 42' outside. 4-For buildings that is equipped with a sprinkler system. A fire department connection shall be located within 200' of a fire hydrant for a 13 type sprinkler system and 750' for a 13R type sprinkler system.</p> |
| 2019-119 | No comment |
| 2019-120 | <p>1-Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs.</p> <p>2- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings. 3-Turn radius 30' inside and 42' outside. 4-For buildings that is equipped with a sprinkler system. A fire department connection shall be located within 200' of a fire hydrant for a 13 type sprinkler system and 750' for a 13R type sprinkler system.</p> |
| 2019-121 | No comment |