

| Acela Number | |
|--------------|--|
| 2019-122 | capable of supporting 80,000 lbs. 2- Fire department access road that exceeds 150' shall provide an approved turnaround. 3- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings. 4- Turn radius 30' inside and 42' outside. |
| 2019-123 | 1- Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs. 2- Fire department access road that exceeds 150' shall provide an approved turnaround. 3- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings. |
| 2019-124 | 1-Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs. 2- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings. 3-Turn radius 30' inside and 42' outside. 4-For buildings that is equipped with a sprinkler system. A fire department connection shall be located within 200' of a fire hydrant for buildings with a sprinkler system. |
| 2019-125 | of supporting 80,000 lbs.2-Fire department access road that exceeds 150' shall provide an approved turnaround. 3-Turn radius 30' inside and 42' outside.4- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings. |
| 2019-126 | 1-Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs. 2- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings. 3-Turn radius 30' inside and 42' outside. 4-For buildings that is equipped with a sprinkler system. A fire department connection shall be located within 200' of a fire hydrant for buildings with a sprinkler system. |

| | |
|----------|--|
| 2019-127 | <p>1-Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs.</p> <p>2- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings. 3-Turn radius 30' inside and 42' outside. 4-For buildings that is equipped with a sprinkler system. A fire department connection shall be located within 200' of a fire hydrant for</p> |
| 2019-128 | <p>1-Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs.</p> <p>2- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings. 3-Turn radius 30' inside and 42' outside. 4-For buildings that is equipped with a sprinkler system. A fire department connection shall be located within 200' of a fire hydrant for 13 type sprinkler system and 750' for a 13R type sprinkler system. 5- Dead end access road that</p> |
| 2019-129 | No comments |
| 2019-130 | <p>1-Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs.</p> |
| 2019-131 | No comments |
| 2019-132 | <p>1-Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs.</p> <p>2- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings. 3-Turn radius 30' inside and 42' outside. 4-For buildings that is equipped with a sprinkler system. A fire department connection shall be located within 200' of a fire hydrant for</p> |
| 2019-133 | No comments |

| | |
|----------|---|
| 2019-134 | <p>1- Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs. 2- Fire department access road that exceeds 150' shall provide an approved turnaround. 3- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings. 4- Turn radius 30' inside and 42' outside. 5- Dead end</p> |
| 2019-135 | <p>1- Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs. 2- Fire department access road that exceeds 150' shall provide an approved turnaround. 3- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings. 4- Turn radius 30' inside and 42' outside. 5- Dead end access road that exceed 150' shall provide ana approved turnaround.</p> |
| 2019-136 | <p>1-Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs. 2- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings. 3-For buildings that is equipped with a sprinkler system. A fire department</p> |
| 2019-137 | <p>1-Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs. 2- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings. 3-Turn radius 30' inside and 42' outside. 4-For buildings that is equipped with a sprinkler system. A fire department connection shall be located within 750' for a 13R type</p> |
| | |