

| Acela Number |  |
|--------------|--|
| 2019-122     | capable of supporting 80,000 lbs. 2- Fire department access road that exceeds 150' shall provide an approved turnaround. 3- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings. 4- Turn radius 30' inside and 42' outside.   |
| 2019-123     | 1- Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs. 2- Fire department access road that exceeds 150' shall provide an approved turnaround. 3- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings. 4- Turn radius 30' inside and 42' outside.  |
| 2019-124     | 1-Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs.<br>2- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings. 3-Turn radius 30' inside and 42' outside. 4-For buildings that is equipped with a sprinkler system. A fire department connection shall be located within 200' of a fire hydrant for buildings that are equipped with a sprinkler system. |
| 2019-125     | of supporting 80,000 lbs.2-Fire department access road that exceeds 150' shall provide an approved turnaround. 3-Turn radius 30' inside and 42' outside.4- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings.   |
| 2019-126     | 1-Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs.<br>2- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings. 3-Turn radius 30' inside and 42' outside. 4-For buildings that is equipped with a sprinkler system. A fire department connection shall be located within 200' of a fire hydrant for buildings that are equipped with a sprinkler system. |

|          |  |
|----------|--|
| 2019-127 | <p>1-Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs.</p> <p>2- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings. 3-Turn radius 30' inside and 42' outside. 4-For buildings that is equipped with a sprinkler system. A fire department connection shall be located within 200' of a fire hydrant for</p>   |
| 2019-128 | <p>1-Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs.</p> <p>2- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings. 3-Turn radius 30' inside and 42' outside. 4-For buildings that is equipped with a sprinkler system. A fire department connection shall be located within 200' of a fire hydrant for 13 type sprinkler system and 750' for a 13R type sprinkler system. 5- Dead end access road that</p> |
| 2019-129 | No comments  |
| 2019-130 | <p>1-Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs.</p>   |
| 2019-131 | No comments  |
| 2019-132 | <p>1-Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs.</p> <p>2- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings. 3-Turn radius 30' inside and 42' outside. 4-For buildings that is equipped with a sprinkler system. A fire department connection shall be located within 200' of a fire hydrant for</p>   |
| 2019-133 | No comments  |

|          |  |
|----------|--|
| 2019-134 | <p>1- Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs. 2- Fire department access road that exceeds 150' shall provide an approved turnaround. 3- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings. 4- Turn radius 30' inside and 42' outside. 5- Dead end</p>   |
| 2019-135 | <p>1- Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs. 2- Fire department access road that exceeds 150' shall provide an approved turnaround. 3- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings. 4- Turn radius 30' inside and 42' outside. 5- Dead end access road that exceed 150' shall provide ana approved turnaround.</p> |
| 2019-136 | <p>1-Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs.<br/>2- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings. 3-For buildings that is equipped with a sprinkler system. A fire department</p>  |
| 2019-137 | <p>1-Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs.<br/>2- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings. 3-Turn radius 30' inside and 42' outside. 4-For buildings that is equipped with a sprinkler system. A fire department connection shall be located within 750' for a 13R type</p>                                   |
|          |  |