



| | | | |
|-----------------------------|----------------------|-----------------------|--------------------------------------|
| Petition #: | 2019- 140 | Review Number: | 1 |
| Petition Respondent: | Bhavana Swayampakala | Date Reviewed: | 11/27/2019 |
| Phone Number: | 704-336-4976 | Email Address: | bhavana.swayampakala@charlottenc.gov |

Comments:

Summary: Water and sewer service is accessible for this rezoning boundary.

Charlotte Water has accessible water system infrastructure for the rezoning boundary via an existing 8-inch water distribution main located along Providence Road West.

Charlotte Water has sanitary sewer system infrastructure accessible for the rezoning boundary via an existing 30-inch gravity sewer main located along Providence Road West.

Development is encouraged to contact Installation Development Services at (704) 336-5499 to review service connection design requirements and City Ordinances (e.g., backflow, separate meter Ordinance, public/private pipeline extensions). Comments: Will need to acquire CAP for meters 1.5” and larger. Has direct access to sewer. Has direct access to water. Contact CLT Water New Services Department for water/sewer services. Contact CLT Private Water for private water systems or contact CLT Water Donated Projects if public infrastructure will be extended through property.

Reservation of sanitary sewer system capacity through the Charlotte Water’s Capacity Assurance Program is the responsibility of the customer/development. Contact the New Services Group at (704) 432-2854 for further information on reserving capacity up to 24 months.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. The findings do not imply available capacity in water and sanitary sewer lines, pump stations, or treatment facilities. Reservation of capacity is achieved through the Charlotte Water’s Capacity Assurance Program.