



Charlotte Storm Water  
600 East Fourth Street  
Charlotte, N C 28202-2844

## *Rezoning Petition Review*

---

**To:** Charlotte Planning, Design & Development

**From:** Doug Lozner

**Date of Review:** January 17, 2020

**Rezoning Petition #:** 19-176

**Existing Zoning:** R-3

**Proposed Zoning:** I-2

**Location of Property:** Approximately 78.68 acres located on the east side of Steele Creek Rd, south of West Blvd and Byrum Dr.

**Site Plan Submitted:** No

**Recommendations Concerning Storm Water:** Flooding and surface water quality impacts associated with impervious surfaces on this site are being addressed through compliance with the Post-Construction Stormwater Ordinance. Compliance may include installing devices that hold and slowly release runoff over time to reduce flooding potential, devices that filter pollutants from runoff before release to streams, preservation of vegetated stream buffer zones, preservation of upland trees and forested areas, or paying a mitigation fee in-lieu-of onsite stormwater control devices. Compliance with the Post-Construction Stormwater Ordinance addresses concerns related to flooding and surface water impacts and therefore staff has no further comments.