



Charlotte Mecklenburg Utility Department
5100 Brookshire Boulevard
Charlotte, NC 28062
Re-Zoning Petition Review

Petition #:	2014-026	Review Number:	1
Petition Reviewer:	Matt Bedford	Date Reviewed:	January 14, 2014
Phone Number:	704-391-5163	Email Address:	mbedford@charlottenc.gov

Comments:
8-inch water main along Bob Beatty road.

8-inch gravity sewer main located on Bob Beatty Road

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.