



CHARLOTTE FIRE DEPARTMENT
700 North Tryon Street
Post Office Box 31097 Charlotte, N.C. 28231-1097

Plan Review Sheet

Petitioner: Janette Skyers
Petition Number: 2006-007
Fire Plans Examiner: R. Turner
Telephone: 704-336-3814

Review: 1
Date Received: 11-7-05
Date Reviewed: 11-14-05
Fax: 704-336-3839

E-Mail: turner@ci.charlotte.nc.us

Remarks :

1. Dead end travel distance limited to 150 feet without means to turn fire apparatus.