



CHARLOTTE FIRE DEPARTMENT
700 North Tryon Street
Post Office Box 31097 Charlotte, N.C. 28231-1097

Plan Review Sheet

Petitioner: The Mcalpine Co.
Petition Number: 2006-013
Fire Plans Examiner: R. Turner
Telephone: 704-336-3814

Review: 1
Date Received: 11-7-05
Date Reviewed: 11-15-05
Fax: 704-336-3839

E-Mail: turner@ci.charlotte.nc.us

Remarks :

1. Min. water supply for two story town homes is 1500 gpm@20 psi.
2. Dead end travel limited to 150 feet without a means to turn fire apparatus.
3. Access required within 150 feet of all exterior walls.
4. All buildings required to have 12 feet clear for ladder rescue.
5. Hydrant required within 750 feet of most remote point of building as truck travels.