



# Charlotte Department of Transportation

## Memorandum

---

---

**Date:** November 25, 2013

**To:** Tammie Keplinger  
Charlotte-Mecklenburg Planning Department

**From:** Michael A. Davis, PE *Mike Davis*  
Development Services Division

**Subject:** Rezoning Petition 14-002: Approximately 1.28 acres located on the northwest corner at the intersection of East Worthington Avenue and Cleveland Avenue.

---

---

CDOT has completed a review of the subject petition in order to ensure consistency with the Transportation Action Plan (TAP). The TAP seeks to ensure that Charlotte's transportation network supports current and future land uses and includes streets that provide safe and comfortable mobility for motorists, pedestrians, bicyclists, and transit users. Based on our review of the petition, we offer the following comments.

### Vehicle Trip Generation

This site could allow for a wide range of trip generation based on the existing zoning. Under the proposed zoning the site could generate approximately 760 trips per day.

We have the following comments regarding apparent conflicts between the proposed rezoning and existing ordinances or policies:

1. The zoning ordinance prohibits vehicular maneuvering within the building setback. The current Porte Cochere design allows for vehicular maneuvering within the setback.

In addition to the comments above, CDOT requests the following changes to the rezoning plan:

1. CDOT cannot support the proposed Porte Cochere as currently designed. CDOT will work with the petitioner to establish a valet operation as needed along the existing curb.
2. We recommend confirming that the proposed 15' drive aisle is adequate width for fire truck access to the site.

The following are requirements of the developer that must be satisfied prior to driveway permit approval. We recommend that the petitioner reflect these on the rezoning plan as-appropriate.

1. According to the City of Charlotte's Driveway Regulations, CDOT has the authority to regulate/approve all private street/driveway and public street connections to the right-of-way of a street under the regulatory jurisdiction of the City of Charlotte.

2. Adequate sight triangles must be reserved at the existing street entrance. Two 35' x 35' and two 10' x 70' sight triangles are required for the entrance(s) to meet requirements. All proposed trees, berms, walls, fences, and/or identification signs must not interfere with sight distance at the entrance(s). Such items should be identified on the site plan.
3. The proposed driveway connections to Cleveland Avenue and East Worthington Avenue will require driveway permits to be submitted to CDOT for review and approval. The exact driveway locations and type/width of the driveways will be determined by CDOT during the driveway permit process. The locations of the driveways shown on the site plan are subject to change in order to align with driveways on the opposite side of the street and comply with City Driveway Regulations and the City Tree Ordinance.
4. All proposed commercial driveway connections to a future public street will require a driveway permit to be submitted to CDOT for review and approval.
5. Any fence or wall constructed along or adjacent to any sidewalk or street right-of-way requires a certificate issued by CDOT.
6. A Right-of-Way Encroachment Agreement is required for the installation of any non-standard item(s) (irrigation systems, decorative concrete pavement, brick pavers, etc.) within a proposed/existing City maintained street right-of-way by a private individual, group, business, or homeowner's/business association. An encroachment agreement must be approved by CDOT prior to the construction/installation of the non-standard item(s). Contact CDOT for additional information concerning cost, submittal, and liability insurance coverage requirements.

If we can be of further assistance, please advise.

C.Leonard

cc: S. Correll  
Rezoning File