



Charlotte Mecklenburg Utility Department
5100 Brookshire Boulevard
Charlotte, NC 28062
Re-Zoning Petition Review

Petition #:	2014-023	Review Number:	1
Petition Reviewer:	Matt Bedford	Date Reviewed:	January 16, 2014
Phone Number:	704-391-5163	Email Address:	mbedford@charlottenc.gov

Comments:

8-inch water main on North Davidson Street. 6-inch water mains on North Caldwell Street, East 15th Street, and East 16th street.

8-inch gravity sewer mains on North Davidson Street, North Caldwell Street, East 15th Street, and East 16th Street.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.