



Charlotte Mecklenburg Utility Department
5100 Brookshire Boulevard
Charlotte, NC 28062
 Re-Zoning Petition Review

Petition #:	2014-045	Review Number:	1
Petition Reviewer:	Matt Bedford	Date Reviewed:	April 16, 2014
Phone Number:	704-391-5163	Email Address:	mbedford@charlottenc.gov

Comments:

Access to the CMUD Water System is available via the existing 36-inch water main along Johnston Road, and the 12-inch and 8-inch water mains along North Community House Road.

Access to the CMUD Sewer Service is available from the existing 8-inch gravity sewer main to the East of parcel under review, at the intersection of North Community House Road and Johnston Road.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.