



**Charlotte Mecklenburg Utility Department**  
5100 Brookshire Boulevard  
Charlotte, NC 28062  
Re-Zoning Petition Review

<b>Petition #:</b>	2014-077	<b>Review Number:</b>	1
<b>Petition Reviewer:</b>	Matt Bedford	<b>Date Reviewed:</b>	July 10, 2014
<b>Phone Number:</b>	704-391-5163	<b>Email Address:</b>	mbedford@charlottenc.gov

**Comments:**

Access to the CMUD Water System is available via the existing 24-inch water main along Lancaster Highway.

Access to the CMUD Sewer Service is not currently available at property under review. The developer will need to make a connection to the existing 8-inch gravity sewer which is located 600 feet to the North along Lancaster Highway. Other connections to the

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.