



**Charlotte Mecklenburg Utility Department**  
5100 Brookshire Boulevard  
Charlotte, NC 28062  
Re-Zoning Petition Review

<b>Petition #:</b>	2014-115	<b>Review Number:</b>	1
<b>Petition Reviewer:</b>	Matt Bedford	<b>Date Reviewed:</b>	October 22, 2014
<b>Phone Number:</b>	704-391-5163	<b>Email Address:</b>	mbedford@charlottenc.gov

**Comments:**

Access to the CMUD water system is available from the existing 8-inch water main along Parker Drive.

Access to the CMUD Sewer System is available from the existing 8-inch gravity sewer main along Parker Drive.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.