



Petition #:	2019-168	Review Number:	1
Petition Respondent:	Bhavana Swayampakala	Date Reviewed:	12/30/2019
Phone Number:	704-336-4976	Email Address:	bhavana.swayampakala @charlottenc.gov

Comments:

Summary: Water service is accessible for this rezoning boundary. Charlotte Water currently does not have sewer system accessible for the rezoning boundary under review. The development will need to donate pipeline infrastructure to CLTWATER to serve this parcel. The applicant should contact Charlotte Water's New Services at (704) 432-2854 for more information regarding accessibility to sewer system connections.

Charlotte Water has accessible water system infrastructure for the rezoning boundary via an existing 16-inch water transmission main located along Oakdale Road.

Charlotte Water currently does not have sewer system accessible for the rezoning boundary under review. The closest available sewer main is approximately 800 feet east of the rezoning boundary on Oakdale Road. A developer donated project will be required in cases there is not direct service. The applicant should contact Charlotte Water's New Services at (704) 432-2854 for more information regarding accessibility to sewer system connections.

Development is encouraged to contact Installation Development Services at (704) 336-5499 to review service connection design requirements and City Ordinances (e.g., backflow, separate meter Ordinance, public/private pipeline extensions). Comments: Will need to acquire CAP. Has direct access to water. Will need to submit plan to Donated Projects for the extension of public sewer. Depending on the required public street network, this site may need to extend public water/sewer to serve their site. Contact our New Services Department for water/sewer services.

Reservation of sanitary sewer system capacity through the Charlotte Water's Capacity Assurance Program is the responsibility of the customer/development. Contact the New Services Group at (704) 432-2854 for further information on reserving capacity up to 24 months.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. The findings do not imply available capacity

in water and sanitary sewer lines, pump stations, or treatment facilities. Reservation of capacity is achieved through the Charlotte Water's Capacity Assurance Program.

