



MECKLENBURG COUNTY
Land Use & Environmental Services Agency

MEMORANDUM

To: Charlotte-Mecklenburg Planning Commission
From: LUESA, Mecklenburg County
Date: 12.22.25
Subject: Rezoning Petition Comments

Charlotte-Mecklenburg Planning Commission
600 East Fourth Street Charlotte, North Carolina 28202

Mecklenburg County has reviewed the City of Charlotte rezoning petition below to identify regulatory requirements of the petitioner; inform the petitioner, planning staff, and other affected parties of such regulatory requirements; and identify potential effects on, and impacts from, nearby properties.

<u>Petitioner Information:</u> Graham Drury The Drox Group, LLC 626 Queens Road #302 Charlotte, NC, 28207 Work Phone: 843-412-4008 graham@droxgroup.com	<u>Parcel GIS ID(s):</u> 21727103, 21727105, 21727106, 21727111, 21727112
<u>Existing Zoning:</u> N1-A <u>Current Use:</u> Single Family	<u>Proposed Zoning:</u> N1-C(CD) <u>Additional Proposed Zoning:</u> No <u>Primary Proposed Zoning:</u> N1-C-CD Neighborhood 1 Zoning District Conditional <u>Request Type:</u> Conditional (Tier 3)

2025-124: McKee Road 50 single family lots

Air Quality Comments: Demolition or renovation of existing structures may require proper notification and removal of asbestos. The petitioner will be notified with the required forms.

The petitioner will be notified of the local dust ordinance requiring property owners, and their contractors, to minimize dust leaving their property.

MCAQ recommends that the parking area for each dwelling be pre-wired for an EV charging station (i.e. EV-ready).

Ground Water Services Comments: Executive Summary: Water supply well registration records noted for parcel 217-271-06. Septic registration records were noted for parcels 217-271-06 and 217-271-11.

Groundwater & Wastewater Services (GWS) records indicate that a water supply well has been registered and located within the bounds of parcel 217-271-06. Water supply wells should be protected during site development by flagging and fencing or be permanently abandoned in accordance with the Mecklenburg County Groundwater Well Regulations prior to site development commencing.

Groundwater & Wastewater Services records indicate a registered septic system exists on parcels 217-271-06 and 217-271-11 listed in the petition. No regulations govern the abandonment of septic systems; however, GWS does recommend that septic tanks be pumped by a NC Licensed Septic Hauler to remove any residual contents and then crushed and backfilled. This recommendation is made because improperly abandoned septic tanks may not be able to support the weight of vehicular traffic, structural foundations or people posing a safety hazard.

Storm Water Services Comments: Properties not in the floodplain no comments

Solid Waste Comments: No comments

Department Contacts:

Petitioners seeking to address individual comments and issues may follow up with the following Mecklenburg County staff:

Air Quality Comments: Megan Green - (megan.green@mecklenburgcountync.gov)

Ground Water Services: Shawna Caldwell - (shawna.caldwell@mecklenburgcountync.gov)

Storm Water Services: Myrette Stephen - (myrette.stephen@mecklenburgcountync.gov)

Solid Waste Comments: Joe Hack - (joe.hack@mecklenburgcountync.gov)

Additionally, please CC Erin Stanforth, (erin.stanforth@mecklenburgcountync.gov) on all communications to individual departments.

MCAQ Scope of Review:

Mecklenburg County Air Quality (MCAQ) has reviewed the petitions with regard to air quality regulations for stationary sources and demolition and/or renovation of structures (e.g. National Emission Standards for Hazardous Air Pollutants for asbestos). Comments may also be made regarding incompatible land uses, sources of Toxic Air Pollutants, proximity to Risk Management Plan facilities, and proximity to known nuisance conditions or sensitive populations. MCAQ has conducted the review based on information submitted by the petitioner, review of aerial photographs (as available through the Mecklenburg County Polaris system), review of the "Air Pollution Facility Information Online" database available from the MCAQ website, and review of Mecklenburg County Health Department

records. The review is cursory based on limited information provided within petition applications and site plans.