



MECKLENBURG COUNTY
Land Use and Environmental Services Agency

August 15, 2007

Mr. Solomon Fortune
Charlotte-Mecklenburg Planning Commission
600 East Fourth Street
Charlotte, North Carolina 28202

Re: Rezoning Petition 2007-126
Approximately 0.62 acres located on the east side of Dunavant Street
between Remount Road and Hawkins Street

Dear Mr. Fortune:

Representatives of the Air Quality (MCAQ), Groundwater & Wastewater Services (MCGWS), Solid Waste (MCSW), Storm Water Services (MCSWS), and Water Quality (MCWQ) Programs of the Mecklenburg County Land Use and Environmental Services Agency (LUESA) have reviewed the above referenced rezoning petition. In order for the Mecklenburg County LUESA to support this rezoning, the following recommendations should be implemented and appear as notes or modifications on site plans:

Air Quality

Development of this site may require submission of an asbestos Notification of Demolition and Renovation to MCAQ due to possible demolition or renovation of an existing structure. A letter of notification and the required forms will be mailed directly to the petitioner by MCAQ.

Groundwater & Wastewater Services

No Comment.

Solid Waste

Mecklenburg County Solid Waste requests the petitioner submit a Solid Waste Management Plan prior to initiating demolition and/or construction activities to include, at a minimum, the procedures that will be used to recycle all clean wood, metal, and concrete generated during demolition and construction activities. Additionally, the plan should specify that all land clearing and inert debris shall be taken to a properly permitted facility. The Plan shall also state that monthly reporting of all tonnage disposed and recycled will be made to the Mecklenburg County Solid Waste Program. The report shall include the identification and location of all facilities receiving disposed or recycled materials.

Mecklenburg County is committed to reduction of construction/demolition waste. Technical assistance is available at no charge to those companies willing to partner with the County in this effort.

Storm Water

No Comment.

Water Quality

No Comment.

Please contact the staff members who conducted the reviews if you have any questions. The reviews were conducted by, Leslie Rhodes (Leslie.Rhodes@mecklenburgcountync.gov) with MCAQ, Jack Stutts (Jack.Stutts@mecklenburgcountync.gov) with GWS, Joe Hack (Joe.Hack@mecklenburgcountync.gov) with MCSW, Bill Tingle (Bill.Tingle@mecklenburgcountync.gov) with MCSWS, and Rusty Rozzelle (Rusty.Rozzelle@mecklenburgcountync.gov) with the MCWQ.

Respectfully,

Heidi Pruess
Environmental Policy Administrator