



Charlotte Storm Water
600 East Fourth Street
Charlotte, N C 28202-2844
OFFC: 704 . 336 . RAIN
FAX: 704 . 336 . 6586

Rezoning Petition Review

To: Keith MacVean, CMPC

From: Matthew Anderson / Doug Lozner / Jeff Hieronymus

Date of Review: December 17, 2007 **(Revised March 28, 2008)**

Rezoning Petition #: 08-33

Existing Zoning: R-4 & O-2

Proposed Zoning: MUDD(CD)

Location of Property: Approximately 2.08 acres located on the west side of Park Road between Heather Lane and Drexel Place

Downstream Complaints and analysis: Downstream complaints consist of flooding and blockage. This site drains to a stream listed as impaired by the NC Division of Water Quality.

Source Citation: A portion of the water quantity and quality comments reference information gained from the "Post-Construction Ordinance Stakeholders' Group Final Report". This report reflects consensus reached during the Council-approved process to include community input on the proposed ordinance language. Other comments, including the environmental permit, stream buffer and some detention requirements reflect existing regulations and ordinances.

Recommendations

Concerning Storm Water: Include the following notes on the petition.

The petitioner acknowledges that other standard development requirements imposed by other city ordinances, standards, policies, and appropriate design manuals will exist. Those criteria, (for example those that regulate streets, sidewalks, trees, storm water, post construction controls, and site development, etc.) will apply to the development site. Conditions set forth in this petition are supplemental requirements imposed on the development in addition to other standards. Where conditions on this plan differ from ordinances, standards, policies, and approaches in existence at the time of formal engineering plan review submission the stricter condition or existing requirements shall apply.

Storm Water Quantity Control

The petitioner shall tie-in to the existing storm water system(s). The petitioner shall have the

Storm Water Quality Treatment – Source: BMP recommendation taken from “Post-Construction Ordinance Stakeholders’ Group Final Report”

Volume and Peak Control – Source: *Volume Control and Peak Control Downstream Analysis taken from “Post-Construction Ordinance Stakeholders’ Group Final Report”.*

For residential projects with greater than 24% BUA, control the peak to match the predevelopment runoff rates for the 10-year and 25-year, 6-hour storms or perform a downstream analysis to determine whether peak control is needed, and if so, for what level of storm frequency. "Residential" shall be defined as "A development containing dwelling units with open yards on at least two sides where land is sold with each dwelling unit."

For commercial projects with less than or equal to 24% BUA, but greater than one acre of disturbed area, control the peak to match the predevelopment runoff rates for the 2 and 10-yr, 6-hr storm.

The following agencies must be contacted prior to construction regarding wetland and water quality permits:

Recommendations Concerning Storm Water Due to January 11th

The petitioner acknowledges that other standard development requirements imposed by other city ordinances, standards, policies, and appropriate design manuals will exist. Those criteria, (for example those that regulate streets, sidewalks, trees, storm water, post construction controls, and

site development, etc.) will apply to the development site. Conditions set forth in this petition are supplemental requirements imposed on the development in addition to other standards. Where conditions on this plan differ from ordinances, standards, policies, and approaches in existence at the time of formal engineering plan review submission the stricter condition or existing requirements shall apply.

**Recommendations
Concerning Storm Water
Due to February 22nd**

Revision: **Add the following note on the petition**

The petitioner acknowledges that other standard development requirements imposed by other city ordinances, standards, policies, and appropriate design manuals will exist. Those criteria, (for example those that regulate streets, sidewalks, trees, storm water, post construction controls, and site development, etc.) will apply to the development site. Conditions set forth in this petition are supplemental requirements imposed on the development in addition to other standards. Where conditions on this plan differ from ordinances, standards, policies, and approaches in existence at the time of formal engineering plan review submission the stricter condition or existing requirements shall apply.

**Recommendations
Concerning Storm Water
Due to March 24th**

Revision: **Add the following note on the petition**

The petitioner acknowledges that other standard development requirements imposed by other city ordinances, standards, policies, and appropriate design manuals will exist. Those criteria, (for example those that regulate streets, sidewalks, trees, storm water, post construction controls, and site development, etc.) will apply to the development site. Conditions set forth in this petition are supplemental requirements imposed on the development in addition to other standards. Where conditions on this plan differ from ordinances, standards, policies, and approaches in existence at the time of formal engineering plan review submission the stricter condition or existing requirements shall apply.