



MECKLENBURG COUNTY
Land Use and Environmental Services Agency

July 15, 2009

Mr. Michael Cataldo
Charlotte-Mecklenburg Planning Commission
600 East Fourth Street
Charlotte, North Carolina 28202

Re: Rezoning Petition 2009-061
Approximately 0.50 acres located on the east corner of East 36th Street
and North McDowell Street

Dear Mr. Cataldo:

Representatives of the Air Quality (MCAQ), Groundwater & Wastewater Services (MCGWS), Solid Waste (MCSW), Storm Water Services (MCSWS), and Water Quality (MCWQ) Programs of the Mecklenburg County Land Use and Environmental Services Agency (LUESA) have reviewed the above referenced rezoning petition.

Programs with No Comment at this Time

Groundwater & Wastewater Services
Solid Waste
Storm Water Services

Recommendations or Ordinance Requirement Reminders

Air Quality

Development of this site may require submission of an asbestos Notification of Demolition and Renovation due to possible demolition or relocation of an existing structure or renovation of a load-bearing wall in an existing structure. This notification is required in accordance with the Mecklenburg County Air Pollution Control Ordinance (MCAPCO) Regulation 2.1110 - Subparagraph (a) - "National Emission Standards for Hazardous Air Pollutants". A letter of notification and the required forms will be mailed directly to the parcel owner.

Please contact the staff members who conducted the reviews if you have any questions. The reviews were conducted by, Leslie Rhodes (Leslie.Rhodes@mecklenburgcountync.gov) with MCAQ, Jack Stutts (Jack.Stutts@mecklenburgcountync.gov) with GWS, Joe Hack

Page 2

(Joe.Hack@mecklenburgcountync.gov) with MCSW, Bill Tingle
(Bill.Tingle@mecklenburgcountync.gov) with MCSWS, and Rusty Rozzelle
(Rusty.Rozzelle@mecklenburgcountync.gov) with the MCWQ.

Respectfully,

Heidi Pruess, Environmental Policy Administrator
Heidi.Pruess@mecklenburgcountync.gov