



October 12, 2009

Attention: Michael Cataldo
Petition #: 2009-077

Proximity to CMUD Water: Existing 16" Water Main accessible East of site on West side of Weddington Road. Existing 6" Water Main accessible South of site on Riseley Lane through a proposed extension.

Proximity to CMUD Sewer: Existing 8" Sewer located East of site along Weddington Road. Existing 8" sewer also accessible South of site in Riseley Lane.