



2010 – 043 – Valley Development

Reviewer: Sarah Poulton

Date: May 21, 2010

Comments:

The plans do not note placement or type of garbage containers or plans for recycling centers. When this property was original submitted in 2006, they did not have to have space for dumpsters because they were planning fewer than 30 units. Now that they are proposing 37 units, they are required to have space for one 8 cubic yard dumpster and 144 square feet of space set aside for recycling receptacles.

Other issues:

None

CC: Brian Garrett, Solid Waste Services