



CHARLOTTE FIRE DEPARTMENT
700 North Tryon Street
Post Office Box 31097 Charlotte, N.C. 28231-1097

Plan Review Sheet

Petitioner: Patrick N. Dillon
Petition Number: 2010-069
Fire Plans Examiner: R. Turner
Telephone: 704-336-3814

Date Reviewed: 1-21-11
Fax: 704-336-3839
turner@ci.charlotte.nc.us

Remarks :

- 1. Dead end travel is limited to 150ft without means to turn fire apparatus. IFC,503.2.5. See rear access parking area.**

All petition comments are to address occupancy compatibility with surrounding properties and or building tenants only. Changes of use, as determined by all or some

Comments by staff will be based on an initial review of conceptual and/or preliminary drawings and project information, and therefore are not to be considered as binding. Submittal of additional information, or a later more detailed evaluation of the plans, including an evaluation made by a field inspector after building permits have been issued, may result in a change in interpretation by the Department as to the application of the NC State Fire Code and Ordinances to the project.

N.C. State Codes, will require determination by the appropriate code enforcement department. For a preliminary Fire Code design meeting, please contact Randy Turner @704-336-3814 or Jeff Wright @ 704-432-1752.

Comments by staff will be based on an initial review of conceptual and/or preliminary drawings and project information, and therefore are not to be considered as binding. Submittal of additional information, or a later more detailed evaluation of the plans, including an evaluation made by a field inspector after building permits have been issued, may result in a change in interpretation by the Department as to the application of the NC State Fire Code and Ordinances to the project.