



---

## PLAN REVIEW SHEET

---

**Date:** 12/14/2011

**Staff Contact:** Tina Votaw

**Telephone:** 704-432-3013

**Petition:** 2012-011


**Email:** tvotaw@charlottenc.gov

**Attachments:** **Waiting Pad Spec. 60.04A**

---

### I. SUMMARY REMARKS:

CATS requests that the Petitioner provide a concrete waiting pad as shown on the attached specification. Please contact Budd Early at CATS (704.432.2557) if there are any questions regarding this request. Thank you.



**PLAN VIEW**  
NTS

**LEGEND**

- NEW CONCRETE WAITING PAD 6" THICK
- NEW CONCRETE WAITING PAD 4" THICK
- TRASH RECEPTACLE
- SIGN
- ADA SPACE
- 5X15 STRUCTURE
- BICYCLE RIB RACK IF REQUIRED

**NOTES:**

1. DIMENSIONS REPRESENT MINIMUM STANDARDS; VARIATIONS MUST BE APPROVED THROUGH CATS AND CDOT PROJECT MANAGER.
2. SEE SHEETS NO. 07A AND 07B FOR ADDITIONAL DETAILS AND NOTES.
3. 2' MINIMUM PLANTING STRIP. 4' PLANTING STRIP IS TYPICAL.

**REVISIONS**

NO.	DATE	DESCRIPTION

APPROVED DATE \_\_\_\_\_

**CHARLOTTE-MECKLENBURG  
LAND DEVELOPMENT  
STANDARDS**



**WAITING PAD WITH 5'X15' BOX SHELTER  
WITH PLANTING STRIP**

STD. NO.	REV.
60.04A	