



## PLAN REVIEW SHEET

**Date:** 6/10/2013  
**Petition:** 2012-102  
Eastway Holdings, LLC

**Staff Contact:** Brian Horton  
**Telephone:** 704-353-0018  
**Email:** bhorton@charlottenc.gov  
**Attachments:** Shelter Pad Details

### I. SUMMARY REMARKS:

The Petitioner is requested to provide a shelter pad for bus service along Central Avenue. The suggested location for the relocated bus stop shelter pad is within the closed driveway on Central Avenue. The pad would replace the existing bus stop currently located near utility access panels.

The conditional plan may either include a development note to locate the shelter pad during the permitting process or show the conceptual location on the site plan. CATS will be responsible for adding the shelter structure to the concrete pad.

The shelter pad is to be located back of the sidewalk within public right-of-way or easement. Between the sidewalk and curb, a connecting access pad must be flush with the sidewalk and level within 2% when measured perpendicular to the street for compliance with the Americans with Disabilities Act (ADA). Below is an image of the standard detail (60.03A) for the requested shelter and access pads. The bicycle pad shown in the below detail may be excluded.

Please contact me if there are any questions relative to this request. Thank you.

