



PLAN REVIEW SHEET

Date: 2/18/2013

Staff Contact: Brian Horton

Telephone: 704-353-0018

Petition: 2013-035
Summit Avenue Freedom Drive LLC

Email: bhorton@charlottenc.gov

Attachments: Concrete Pad Spec

I. SUMMARY REMARKS:

We request that the Petitioner provide a waiting pad for bus service along West Morehead Street. The pad may be located where a driveway is requested by CDOT to be closed.

The size and specification of the concrete waiting pad at the bus stop would be located between the existing curb and the existing sidewalk and be 5 feet in width. Pad must be flush with sidewalk and level within 2% when measured perpendicular to street for compliance with the ADA. Below is an image of the standard (CLDSM – 60.01A) waiting pad.

Please contact me if there are any questions relative to this request. Thank you.

