



Charlotte Mecklenburg Utility Department
5100 Brookshire Boulevard
Charlotte, NC 28062
 Re-Zoning Petition Review

Petition #:	2014-054	Review Number:	1
Petition Reviewer:	Matt Bedford	Date Reviewed:	May 10, 2014
Phone Number:	704-391-5163	Email Address:	mbedford@charlottenc.gov

Comments:

Access to the CMUD Water System is available via the existing 16-inch and 8-inch water mains on Central Avenue, and the 20-inch and 8-inch water mains on North Sharon Amity Road.

Access to the CMUD Sewer Service is available via the existing 8-inch gravity sewer mains located along Central Avenue and North Sharon Amity Road.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.