



Charlotte Mecklenburg Utility Department

5100 Brookshire Boulevard

Charlotte, NC 28062

Re-Zoning Petition Review

Petition #:	2015-012	Review Number:	1
Petition Reviewer:	Matt Bedford	Date Reviewed:	December 22, 2014
Phone Number:	704-391-5163	Email Address:	mbedford@charlottenc.gov

Comments:

Access to the CMUD Water System is available via the existing 6-inch water mains along East 35th Street and Yadkin Avenue.

Access to the CMUD Sewer Service is available from the existing 8-inch gravity sewer mains along East 35th Street and Yadkin Avenue.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.