



Charlotte Mecklenburg Utility Department
5100 Brookshire Boulevard
Charlotte, NC 28062
Re-Zoning Petition Review

Petition #:	2015-022	Review Number:	1
Petition Reviewer:	Matt Bedford	Date Reviewed:	December 22, 2014
Phone Number:	704-391-5163	Email Address:	mbedford@charlottenc.gov

Comments:

Access to the CMUD Water System is available via the existing 16-inch water mains along Ardrey Kell Road and Providence Road, and the existing 8-inch water mains along Golf Links Drive and Allison Woods Drive.

Access to the CMUD Sewer Service is available from the existing 8-inch gravity sewer along Wheat Ridge Road, and the existing 8-inch gravity sewer main that runs along the stream on the northeast side of parcel.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.