



Petition #:	2015-035	Review Number:	1
Petition Reviewer:	Matt Bedford	Date Reviewed:	January 21, 2015
Phone Number:	704-391-5163	Email Address:	mbedford@charlottenc.gov

Comments:

In relation to the parcels under review, Charlotte Water has water system availability via the existing 8-inch water mains along South Church Street and West Bland Street.

In relation to the parcels under review, Charlotte Water has sewer system availability via the existing 8-inch gravity sewer mains South Church Street and West Bland Street.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.