



<b>Petition #:</b>	2015-049	<b>Review Number:</b>	1
<b>Petition Reviewer:</b>	Matt Bedford	<b>Date Reviewed:</b>	March 23, 2015
<b>Phone Number:</b>	704-391-5163	<b>Email Address:</b>	mbedford@charlottenc.gov

**Comments:**

In relation to the parcel under review, Charlotte Water has water system availability via the existing 2-inch water main along Odum Avenue.

In relation to the parcel under review, Charlotte Water has sewer system availability via existing 8-inch gravity sewer main along Odum Avenue.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.