



<b>Petition #:</b>	2015-055	<b>Review Number:</b>	1
<b>Petition Reviewer:</b>	Matt Bedford	<b>Date Reviewed:</b>	March 23, 2015
<b>Phone Number:</b>	704-391-5163	<b>Email Address:</b>	mbedford@charlottenc.gov

**Comments:**

In relation to the parcels under review, Charlotte Water has water system availability via the existing 16-inch, 12-inch, and 8-inch water mains along Providence Road.

In relation to the parcels under review, Charlotte Water has sewer system availability via existing 8-inch gravity located at intersection of Province Road and Providence Country Club Drive. Sewer system availability is also available via the existing 8-inch gravity sewer main along Providence Road at intersection of Golf Links Drive.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.