



MECKLENBURG COUNTY
Land Use and Environmental Services Agency

May 29, 2015

Ms. Zenia Duhaney
Charlotte-Mecklenburg Planning Commission
600 East Fourth Street
Charlotte, North Carolina 28202

Re: Rezoning Petition 2015-087

Location: 72.2 acres located on the east side of Providence Road between Interstate 485 and Providence Country Club Dr.

Dear Ms. Duhaney:

Representatives of the Air Quality (MCAQ), Groundwater & Wastewater Services (MCGWS), Solid Waste (MCSW), Storm Water Services (MCSWS), and Water Quality (MCWQ) Programs of the Mecklenburg County Land Use and Environmental Services Agency (LUESA) have reviewed the above referenced rezoning petition.

Programs with No Comment at this Time

Solid Waste
Air Quality
Groundwater & Wastewater Services

Recommendations and/or Ordinance Requirement Reminders

Water Quality

General Comments: The requirements of the post-construction storm water ordinance for the City of Charlotte should be applied to the proposed rezoning. More detailed information regarding ordinance requirements is available at the following website: <http://charmeck.org/stormwater/regulations/Pages/Post-ConstructionStormWaterOrdinances.aspx> and click on City of Charlotte.

Specific Comments:

The parcel identified by parcel number 23113105 includes a tributary of Six Mile Creek. Surface water buffers on this site include a 100 foot undisturbed Post-Construction and a 200 foot undisturbed Post-Construction.

No further comments on the above petition at this time.

Please contact the staff members who conducted the reviews if you have any questions. The reviews were conducted by, Megan Green (Megan.Green@mecklenburgcountync.gov) with MCAQ, Dennis Tyndall (Dennis.Tyndall@mecklenburgcountync.gov) with GWS, Joe Hack (Joe.Hack@mecklenburgcountync.gov) with MCSW, and Rusty Rozzelle (Rusty.Rozzelle@mecklenburgcountync.gov) with MCWQ.

Respectfully,

Jeanne Quinn, Administrative Support Supervisor
Jeanne.quinn@mecklenburgcountync.gov