



<b>Petition #:</b>	2015-125	<b>Review Number:</b>	1
<b>Petition Reviewer:</b>	Brady Glover	<b>Date Reviewed:</b>	October 6, 2015
<b>Phone Number:</b>	704-391-5171	<b>Email Address:</b>	brady.glover@charlottenc.gov

**Comments:**

In relation to the parcels under review, Charlotte Water has water system availability via the existing 6-inch water mains located along North Brevard Street, North Caldwell Street, and Belmont Avenue. Additionally, Charlotte Water has water system availability via an existing 12-inch water main located along North Brevard Street and an existing 8-inch water main located along North Davidson Street.

In relation to the parcels under review, Charlotte Water has sewer system availability via the existing 8-inch gravity sewer mains located along North Brevard Street, Belmont Avenue, and North Davidson Street.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.