



<b>Petition #:</b>	2016-025	<b>Review Number:</b>	1
<b>Petition Reviewer:</b>	Brady Glover	<b>Date Reviewed:</b>	December 11, 2015
<b>Phone Number:</b>	704-391-5171	<b>Email Address:</b>	brady.glover@charlottenc.gov

**Comments:**

In relation to the parcel under review, Charlotte Water has water system availability via the existing 8-inch water main located along Wright's Ferry Road.

In relation to the parcel under review, Charlotte Water has sewer system availability via the existing 8-inch gravity sewer main located along Wright's Ferry Road.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.