



Petition #:	2016-028	Review Number:	1
Petition Reviewer:	Brady Glover	Date Reviewed:	December 11, 2015
Phone Number:	704-391-5171	Email Address:	brady.glover@charlottenc.gov

Comments:

In relation to the parcel under review, the closest existing water main is located approximately 250 feet southwest of the southern corner of the property. The applicant should contact Charlotte Water's New Services at (704) 432-5801 for more information regarding accessibility to this water main.

In relation to the parcel under review, Charlotte Water has sewer system availability via the existing 8-inch gravity sewer mains located along Old Statesville Road.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.