

Petition #:	2016-040	Review Number:	1
Petition Reviewer:	Brady Glover	Date Reviewed:	January 14, 2016
Phone Number:	704-391-5171	Email Address:	brady.glover@charlottenc.gov

Comments:

In relation to the parcels under review, Charlotte Water has water system availability via existing 8-inch water mains located along Providence Country Club Drive and Golf Links Drive. An existing 12-inch water main is located along Providence Road that extends approximately 300 feet north of the intersection at Providence Road and Providence Country Club Drive.

In relation to the parcels under review, Charlotte Water has sewer system availability via existing 8-inch gravity sewer mains located along Providence Country Club Drive and Providence Road. It should be noted there are no existing sewer mains between Development Areas 'C' and 'E' (as shown on Technical Data Sheet – RZ-1) along Providence Road.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.