



Petition #:	2016-091	Review Number:	1
Petition Reviewer:	Alan H. Gaines	Date Reviewed:	May 9, 2016
Phone Number:	704-391-4689	Email Address:	againes@ci.charlotte.nc.us

Comments:

In relation to the parcel under review, Charlotte Water has water system availability for the rezoning boundary via an existing 8-inch water distribution main located along North Davidson Street. There is also system availability via an 8-inch water distribution main located along North Brevard Street and an existing 6-inch water distribution main located within the rezoning boundary along East 33rd Street.

In relation to the parcel under review, Charlotte Water has sewer system availability for the rezoning boundary via existing 8-inch gravity sewer mains located along East 33rd Street and North Davidson Street. There is also system availability via existing 15-inch and 8-inch gravity sewer mains located along North Brevard Street.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.