



<b>Petition #:</b>	2017-011	<b>Review Number:</b>	1
<b>Petition Reviewer:</b>	Alan H. Gaines	<b>Date Reviewed:</b>	October 27, 2016
<b>Phone Number:</b>	704-391-4689	<b>Email Address:</b>	againes@ci.charlotte.nc.us

**Comments:**

In relation to the parcels under review, Charlotte Water currently does not have water system availability via a water distribution main. The closest water distribution main is approximately 380 feet south of the property at the intersection of Kenilworth Avenue and Greenwood Cliff. The applicant should contact Charlotte Water's New Services at (704) 432-5801 for more information regarding accessibility to water system connections.

In relation to the parcels under review, Charlotte Water has sewer system availability for the rezoning boundary via an existing 24-inch gravity sewer main located along through the rezoning boundary.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.