## **Rezoning Transportation Analysis**

Petition Number: 2017-147

General Location Identifier: 03904407, 0394405

From: Kelsie Anderson, PE Reviewer: Rick Grochoske

Kelsie.Anderson@charlottenc.gov rgrochoske@charlottenc.gov

704-432-5492 704-432-1556

**Revision Log:** 

Date	Description	
10-24-2017	First Review	
11-17-2017	Second Review	

#### **General Review Information**

The site is on Brookshire Blvd (major thoroughfare) between N Cloudman St. (local) and N Hoskins Rd (minor thoroughfare) and is located in a wedge outside Route 4

CDOT's review of this rezoning petition is intended to ensure consistency with the Transportation Action Plan (TAP) which seeks to ensure that the City's transportation network supports current and future land uses and includes streets that provide safe and comfortable mobility for motorists, pedestrians, bicyclists, and transit users.

This document is primarily for communication to Planning Department staff as part of the overall City staff analysis of the rezoning petition and includes an overall summary of the case from a transportation perspective, information on trip generation, and resolved or outstanding site plan concerns. Additional advisory information about the driveway permit process is provided for information only.

Based on our review of the petition, we offer the following information for your consideration.

### **Transportation Summary**

This site is on a major thoroughfare between a signalized intersection with a minor thoroughfare and an unsignalized intersection with a local street. CDOT requests that the petitioner commit to reconstruction of the curb ramps at the site's curb return on Couldman to support the City's project for curb ramp reconstruction on the other corners.

#### **Trip Generation**

Scenario	Land Use	Intensity	Trip Generation (vehicle trips/day)	Source
Existing Use	Vacant	N/A	0	Tax Record
Entitlement with Current Zoning	Convenience market with gasoline pumps	16 Fueling Positions	8,700	RZ 2016-084
Proposed Zoning	Convenience market with gasoline pumps	16 Fueling Positions	8,700	Site Plan: 07-20-16

## **Outstanding Issues**

Strikeout = Not an outstanding issue

- 1. Traffic Study A Traffic Impact Study/Transportation Technical Memorandum is not needed for the complete review of this petition.
- 2. The petitioner should revise the site plan and add conditional note(s) to provide two (2) directional accessible ramps on the site's corner of Brookshire Hwy. and Cloudman St. These ramps will align with ramps currently being constructed at the corner adjacent to the site.

# **Rezoning Transportation Analysis**

Petition Number: 2017-147

General Location Identifier: 03904407, 0394405

#### **Advisory Information**

The following are requirements of the developer that must be satisfied prior to driveway permit approval. We recommend that the petitioner reflect these on the rezoning plan as-appropriate.

- 1. According to the City of Charlotte's Driveway Regulations, CDOT has the authority to regulate/approve all private street/driveway and public street connections to the right-of-way of a street under the regulatory jurisdiction of the City of Charlotte.
- 2. Adequate sight triangles must be reserved at the existing/proposed street entrance(s). Two 35' x 35' sight triangles (and two 10' x 70' sight triangles on North Carolina Department of Transportation on NCDOT maintained streets) are required for the entrance(s) to meet requirements. All proposed trees, berms, walls, fences, and/or identification signs must not interfere with sight distance at the entrance(s). Such items should be identified on the site plan.
- 3. The proposed driveway connection(s) to public streets will require a driveway permit(s) to be submitted to CDOT (and the North Carolina Department of Transportation on NCDOT maintained streets) for review and approval. The exact driveway location(s) and type/width of the driveway(s) will be determined by CDOT during the driveway permit process. The locations of the driveway(s) shown on the site plan are subject to change in order to align with driveway(s) on the opposite side of the street and comply with City Driveway Regulations and the City Tree Ordinance.
- 4. All proposed commercial driveway connections to a future public street will require a driveway permit to be submitted to CDOT for review and approval.
- 5. Any fence or wall constructed along or adjacent to any sidewalk or street right-of-way requires a certificate issued by CDOT.
- 6. A Right-of-Way Encroachment Agreement is required for the installation of any non-standard item(s) (irrigation systems, decorative concrete pavement, brick pavers, etc.) within a proposed/existing City maintained street right-of-way by a private individual, group, business, or homeowner's/business association. An encroachment agreement must be approved by CDOT prior to the construction/installation of the non-standard item(s). Contact CDOT for additional information concerning cost, submittal, and liability insurance coverage requirements.