



To: Tammie Keplinger, CMPC

From: Ashley Botkin, Engineering Land Development

Date: January 26, 2018

Rezoning Petition #: 2017-183 Revised

Detailed construction plans for the proposed site development are to be submitted for review and approval to the City of Charlotte's Land Development Division **after land entitlement (approved rezoning)**. Staff from City Land Development, Charlotte DOT, and the Planning Department review and inspect development projects in order to ensure compliance with pertinent City ordinances and standards. Please note Building Permit applications can be submitted concurrently to Mecklenburg County Code Enforcement and permit issuance will be conditioned upon the City of Charlotte's plan approval as required. Additional information may be found at our website: <http://development.charmeck.org>.

The Petitioner acknowledges that in addition to the conditions set forth in this petition and in the Zoning Ordinance, development requirements imposed by other City ordinances, construction standards, and design manuals do exist, are not waived or modified by the rezoning approval, and may be applicable to the proposed development. These development requirements include the regulation of streets, sidewalks, trees, and storm water. Where the conditions set forth in this Rezoning Plan conflict with other City development requirements, the stricter condition or requirement shall apply.

**Comments for this rezoning:**

Tom Ferguson (Engineering) – Please delete the phrase "DEVELOPMENT OF" from the existing note H1 under the ENVIRONMENTAL FEATURES heading.

Peter Grisewood (Urban Forestry) – Site is in a wedge and will be required to provide 15% tree save area based on gross acreage. 15% of 3.01 acres = 0.45 acres tree save. Show tree save area on site map in common open space. Show calculations for tree save area on site plan. Tree save must contain existing healthy tree canopy. Tree save must be 30' width minimum.

Strike language on site map referring to potential tree save containing areas where “existing trees are not preserved”.

Jay Wilson (Erosion Control) –