

Acela Number	
2018-001(c)	Access road shall be within 150' of nonsprinklered building. Fire hydrant shall be within 750' of most remote point of building as truck travels. Maintain 20' unobstructed access road width at all times for fire department access. No on street parking on road less than 26' clear width.